
## LCD Display Unit User Manual



RM-5B (Bluetooth version) RM-5 (Standard version)

Dear users,
Thank you for choosing our product!

This user manual provides important information and advice on installation, usage, parameter settings, troubleshooting methods, etc. Before using the product, please read this manual carefully.

## Table of Contents

12	11. Common Problems and Solutions
12	10.9 Bluetooth connection status
12	10.8 Device information
11	10.7 Historical data of the current day
10	10.6 Statistic data
10	10.5 Load modes
10	10.4.4 "Clear historical data" and "Reset to factory settings"
9	10.4.3 Controller abnormality voice alarm on/ off setting
9	10.4.2 LCD screen backlight time setting
9	10.4.1 Controller charging and discharging related parameters setting
oo .	10.4 Parameter Settings
7	10.3 Real-time monitoring
6	10.2 Main menu
5	10.1 Menu block diagram
4	10. System Menu and Parameter Settings
4	9. Fault Indication and Communication Indication
3	8. Usage of Navigation Keys
3	7. Parameter Details
3	6. Data Cable Definition ————————————————————————————————————
2	5. Installation Instructions
1	4. Packing List
	Usage Recommendations and Precautions————————————————————————————————————
1	2. Function Descriptions
	1. Product Features

#### 1. Product Features

- 1) Adopts a 128\*64 LCD screen, with the menus designed with numeric and graphic forms
- 2) With a graphical design, the main menu is artistic as well as informative: it can display up to 10 Able to read the historical data of a certain day. parameters and states
- 5) Employs two indicator lights to indicate controller abnormalities and communication errors 4) A low-power-consumption BLE4.0 feature enables more powerful functions when pairing with a mobile APP (optional)
- 6) Features a controller abnormality voice alarm function which can be switched on/ off.
- 7) A backlight time setting function is available

- 8) Able to monitor live data and operating statuses of the controller. On/ off switching, clearing of historical data and restoring to factory settings can all be done with this unit.
  9) Adoption of standard Modbus communication protocol.
  10) Features standard RJ12 as the communication interface. 11) With no need of an external power source, connection with a controller by means of a data cable will
- 12) Boasis an industrial grade design and excellent anti-interference capacity, the product can function be enough to enable the unit to be powered.

#### 2. Function Descriptions

well in various tough conditions.

With the menus and operations on the navigation keys, the following functions can be realized:

1) Real-time monitoring and checking of live data, charging and discharging parameters, load state,
fault codes, historical data, device information, etc. of an individual controller;

- Setting of related charging and discharging parameters;
   Load mode setting, load on/ off switching (manual mode);
- 4) With the optional bluetooth-version display unit, more powerful functions can be realized with the help of a mobile App. (Model: RM-5B)

## 3. Usage Recommendations and Precautions

- correct usage of the product. 2) This LCD display unit is to be used only with our company's controllers, thus please make necessary 1) On receiving the product, carefully read all instructions and precautions in this manual so as to ensure
- confirmations with the sales person before purchasing.

  3) If you want to purchase a data cable or make one by yourself, strictly observe the instructions in the "Data Cable Definition" part of this manual, otherwise you may damage the display unit or the controller.

  4) The displayed data will be updated every 3 seconds, thus the data on the screen will slightly lag behind the real-time system data, which is a normal phenomeno 5) Never put this product in environments subject to the influence
- moisture, corrosion, strong electromagnetic interference, etc. e of direct sunshine, rain, heavy dust
- 6) Never attempt to disassemble and repair this product by yourse

#### 4. Packing List


Item	Quantity	Remarks
LCD display unit	1	
Data cable (2m)		6 cores. RJ12 at both ends
User manual	1	
Tapping screws KA3*12mm	4	For installation on a panel
Tanning screws KAA*25mm		-
lapping screws KA4"25mm	4	7
Plastic expansion bolts M6*25mm	4	For installation on a wall

#### 5. Installation Instructions

## 5.1. Installation on a controller case or panel

External dimensions: 115.82×115.82mm Installation dimensions: 96mm or 103.82x103.82mm Installation hole diameter: \$3.5 (mm)

Front






Right view


1 1 A


000000



#### 5.2 Installation on a wall

External dimensions: 118.5×118.5×48mm Installation dimensions: 50×50mm or 70×70mm Installation hole diameter: ¢ 5(mm)







N

6. Data Cable Definition

Controller communication port RJ12 and the core series number is as follows:



#### 7. Parameter Details

Dimensions 115.82×115.82	Product weight 0.5	Operating temperature -35°C to+65°C	Communication port RS2	Baud rate 9600	Communication port RJ12 (	paor	Static power consumption LCD backlight of
115.82×115.82 (mm) (L×W)	0.5kg	to+65°C;	RS232	9600bps	RJ12 (6-pin)	LCD backlight off <25mA/12V	LCD backlight on <35mA/12V

### 8. Usage of Navigation Keys

The product design features 4 keys which, from left to right, are: " $oldsymbol{\odot}$ ", " $oldsymbol{\odot}$ ", " $oldsymbol{\odot}$ ", "lock") They equal to ("UP", "DOWN", "ESC", "OK")

Key	Operation	Description
•	Tap, press and hold	When browsing a menu , tap the key for a page up;     In parameter setting, tap the key to increase the value by a minimum unit;     Press and hold the key for quick page-up movement or value increasing.
•	Tap, press and hold	When browsing a menu, tup the key for a page down;     In parameter setting, tap the key to decrease the value by a minimum unit;     Press and hold the key for quick page-down movement or value decreasing.
	Тар	<ol> <li>When browsing a menu, tap the key to return to the previous level, until the main menu is reached;</li> <li>In the setting mode, a tap on this key can cancel the data modification in process and exit the setting mode.</li> </ol>
	Press and hold	In any menu, press and hold the key to immediately skip to the "error code page for convenient checkup.
	Тар	<ol> <li>In a menu which contains submenus, tap the key to enter into a submenu;</li> <li>In a menu with settable or adjustable parameters, tap the key to enter into or confirm parameter setting.</li> </ol>
•	Press and hold	If "manual mode" is selected as the load mode, a press-and-hold on the key to switch on/ off the load.  If it's not in the manual mode, a press-and-hold will cause the display to skip to the load mode setting interface as a reminder.  (Note: if no load is connected to the controller, this function and related load mode setting interface as a reminder.

## 9. Fault Indication and Communication Indication

Communication fault indicator Communication connection indicator



C connection indicator	(()) Communication	C) otom lagit illulogion	A System fault indicator	Indicator
Slow flashing	Steady off	Quick flashing	Steady off	State
Communication connection between the LCD display unit and controller abnormality	Communication connection between the LCD display unit and controller is normal	Abnormality occurs to the controller system(Please check the error code)	The controller system is normal	Description

# When the "startup screen" is displayed, tap any key to skip it. If no operation is detected within 5 seconds, a "Connecting" interface will ensue:

10. System Menu and Parameter Settings




"Connecting" interface. When connection is successfully done, the "main menu" will appear:


Solar Controller

Connect ing...

#### 10.1 Menu block diagram



of the above menus, related parameters setting, etc. Refer to "Usage of Navigation Keys" for operations including entering into and exiting each (This menu is available only to the display units with the optional bluetooth function)



Definitions of "main menu" icons

#### 10.3 Real-time monitoring

(This menu is contained in and supplementary to information of the main menu) In the "main menu", tap "⊙" to enter into this menu; continue to tap "⊙, ⊙" to switch between menus; or tap "⊙" to return to the "main menu". (Refer to "8. Usage of Navigation Keys" for operation)

			menus	2nd-level									Menu level
4		1	ω	1		_	J					ь	Page
Fault :	MaxBatVol :	MinBatVol :	LoadPower :	ChagPower:	DevTemp :	BatSoc:	LoadCrt:	LoadState :	ChagCrt :	PvVol:	BatVol :	ChagState:	parameter
NOL	13.0V	12.5V	WO	WO	27 °C	100%	OA	OFF	0A	VO	11.6V	IDLE .	ter/
Controller error codes:  BAT-LDV " over-discharge BAT-DVD" over-voltage BAT-UVW " under-voltage warning "L-SHTCRT" load short-circuit "L-OVRCRT" load over-current "DEV-OVRTMP" internal over-temperature "BAT-OVRTMP" battery over-temperature "PV-OVP"solar panel over-voltage "PV-MP-OVD" solar panel working over-voltage "PV-MP-OVD" solar panel reverse-connection	The current day's max. battery voltage	The current day's min. battery voltage	Discharging power	Charging power	Controller temperature	Remaining battery capacity	Load current	Load in "ON" or "OFF" state	Charging current	Solar panel voltage	Battery voltage	Charging state indications: "IDLE", no charging "MPPT",MPPT charging "EQU", equalizing charging "BST", boost charging "FLT", floating charging "LIMIT", current-limited charging	Description
Not every controller has all of these error codes. For details, refer to the User Manual of the corresponding controller.													Remarks

#### 10.4 Parameter Settings

menu 3 3 5 4 4	<u>νν</u> ΘΙ	<u>\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\</u>	<u>ĕ</u>	<u>⊌</u>	<u>⊌</u>	<u> </u>	vel	vel	ve.	vel.	vel .	9Vel	2 st-level menu	2 st-level			2					ц		Menu level Page	and the second of the second o
Light control voltage LCD screen backlight time Fault voice alarm; Clear historical data	Light control voltage LCD screen backlight time Fault voice alarm;	Light control voltage LCD screen backlight	Light control voltage	(	Light control time	Temperature compensation	Equalizing charging interval	Boost charging time	Equalizing charging time	Over-discharge time delay	Over-discharge voltage	Under-voltage warning level	Over-discharge recovery voltage	Boost charging recovery voltage	Floating charging voltage	Boost charging voltage	Equalizing charging voltage	Charging limit voltage	Over-voltage threshold	Device address	Nominal battery capacity	Battery type	Battery system voltage	Item to set	0,
storyDat	1000000	Voice Alarm :	BackLight-T :	L-CON-V:	L-CON-T:	Temp-Com:	Equ-Inv :	Bst-Time:	Equ-Time:	LVD Delay:	LowVolDsc :	UndVolWrn :	LowVoiRev :	BstChgRev .	FltChgVol :	BstChgVol :	EquChgVol:	ChgLimtVol :	OverVoiDsc ;	Address :	Capacity :	BatType :	BatSysVol :	Displayed item/ parameter	
Select "YES" for execution		"ON", voice alarm enabled "OFF", voice alarm disabled	1 to 600s (ON indicates the screen is lit constantly)	5~11V	0-60 MIN	-(3~5)mV/°C/2V	0~30 D(days)	0~300 MIN	0~300 MIN	0~60s	9.0~17.0V	9.0~17.0V	9.0~17.0V	9.0~17.0V	9.0~17.0V	9.0~17.0V	9.0~17.0V	9.0~17.0V	9.0~17.0V	1~60	0~9999	"SLD" sealed lead-acid battery "FLD" open lead-acid battery "GEL" gel battery "LI" lithium battery "USE" user defined	"12V" 12V system "24V" 24V system "36V" 36V system "48V" 48V system "AUTO" auto recognition	Parameter and setting range	
			H H	*n ,± 1	1+	H 1	H →	+ 1	± 1	H H					*n , ±1					+ 	± 5			Remarks	

ω

Note:

1) In this manual, "n" assigned with a value of 1, 2, 3 or 4 denotes a battery system of 12V, 24V, 36V or 48V accordingly. System voltage indication

2) Before setting parameters, first refer to the User Manual of the corresponding controller. As some parameters are not settable, operation of setting these parameters on the display unit will be deemed as invalid or impossible by the controller.



- ① The "parameters setting" page will have a brief summary of the parameters already set in this menu;
  ② "AUTO": the battery voltage is the automatic recognition system;
  ③ "SLD": battery type is sealed lead acid battery;
  ④ "BST": charging voltage is 14.4V\*n;
  ⑥ "IVD": over-discharge voltage is 11.0V\*n;
  ⑤ "IVD": over-discharge voltage is 11.0V\*n;
  ⑥ In the "parameters setting manual, tap "N" to enter into the following submenus.

# 10.4.1 Controller charging and discharging related parameters setting

- ① . All voltage values are to be set based on 12V system settings. For example, for a 24V system, if the over-discharge voltage is to be set to 22 0V, as n=24/12=2, the value needed in line with 12V system settings is 22.0V/2=11.0V, therefore the over-discharge voltage needs to be set to 11.0V.
  ② . Tap "② . ② to select the item to be set; then tap "②", and the parameter or sign will flash; continue to tap "③ . ③ "to adjust the value, and tap "④" again to confirm the setting. (For the setting ranges of related parameters, refer to "Parameter settings list")
- For parameters on the current menu, those highlighted are settable, while those underlined are not)

## 10.4.2 LCD screen backlight time setting

The setting range of LCD screen backlight time is 1 to 600s	208	BackLight-T:
The LCD screen is lit constantly	ON	BackLight-T:
Description	item/ parameter	Displayed

mode, and tap " ①, ② " to modify the value within the setting range ("ON" indicates the screen will be constantly lit, and the range of backlight time is "1-600" S.). Tap " ② " to confirm the modification, or tap " ③ " to cancel the modification. Enter into the setting menu, tap ". O. "to move to "BackLight-T: 20S", tap ". O"to enter into the setting

## 10.4.3, Controller abnormality voice alarm on/ off setting

Buzzer state	Alarm type
No Alarm	System running well or wa
Alarming 1min	Battery over-discharge, Load short circuit/overload, controller or battery over-temperature
Alarming 15s	Battery under-voltage
Alarming persistent	Battery over-voltage, solar panel reverse connection, solar panel over voltage

Voice alarm disabled

Voice alarm enabled

Description

Voice Alarm: OFF Voice Alarm: ON Displayed item/ parameter

Enter into the setting manual, tap " (a), (b) " to move to "Voice Alarm: XXX", tap " (b) " to enter into the parameter setting mode, and again use " (a), (b) " to switch between "ON" and "OFF". Tap " (b) " to confirm the modification, or tap " (b)" to cancel the modification.

Factory settings disable the voice alarm function by default (the aforementioned faults will not trigger alarms with the voice alarm disabled).

## 10.4.4, "Clear historical data" and "Reset to factory settings"

"CIrHistoryData" --> "YES" clear historical data

"RestoreDefault"--> "YES"reset to factory settings

Tap "① " to enter into the submenu, and a "NO" and YES" selection menu will pop up. Use " ④ .① "
to select" YES", then tap "①" again, and "YES" will flash a few times. If "NO" is selected, tap "②" to
directly return to the previous level.

#### 10.5 Load modes

Load mode setting icon -



1). If the characters displayed on top of "<Mode>" are "ON", it indicates that the load is switched on, and "OFF" indicates the load is switched off.

"OFF" indicates the load is switched off.

2). Tap "O" is center into the load setting mode, and right below the "<Mode>", the mode characters or digits will begin to flash. Use "④, • "to select any one from the load modes listed in the following table,


and tap "D" again to complete the load mode setting.

3). Press and hold "D" in any menu but not the setting mode: if the current load mode is "manual mode", pressing and holding the key will switch on/ off the load; if the current load mode is not "manual mode", pressing and holding the key will cause the display to skip to the load mode setting interface and a pressing and holding the key will cause the display to skip to the load mode setting interface and a reminder will pop up telling the user in this mode, pressing and holding the key will not switch on/ off the

4). Note: this parameter is ineffective for controllers without loads.

Load mode	Mode	Description
Sole light control mode	Light+On	The solar panel voltage is lower than the light control on voltage, and after a preset time delay, the controller will switch on the load; The solar panel voltage is higher than the light control off voltage, and after a preset time delay, the controller will switch off the load.
Light control + time control mode 1 to 14H	Light+ 01H Light+ 14H	The solar panel voltage is lower than the light control on voltage, and after a time delay, the controller will switch on the load. From this point on, the load will work for a preset period of time (1 to 14 hours) before being switched off
Manual mode	Manual	In this mode, whether it's day or night, users can press and hold the "OK" key to switch on or off the load; this mode is often used in some special occasions or during commissioning.
Debugging mode	Debug	As long as the solar panel voltage is lower than the light control on voltage, the controller will immediately switch on the load;  As soon as the solar panel voltage gets higher than the light control off voltage, the controller will immediately switch off the load.  This mode is usually used during system installation and commissioning.
Normal on mode	Normal On	This mode is suitable for applications requiring 24-hour operation, and after being switched on, the load keeps outputting in this mode.

#### 10.6 Statistic data



Including total charging amp-hrs operating days, over-discharges nbers of

2	TOTAL	I'	
ANALYSI	DAYS:	DAYS: 9—Number of operating days: 9  ANALYSI LVDC: 5—Number of over-discharges:5	ys: 9 jes:5
s, total dischargii and full-charges	ng amp-	s, total discharging amp-hrs, total power consumption, num and full-charges	on, num

		2nd-level menus					Menu level
	N			-			Page
FUL-Co	LVD-Co	Rundays	E-lod:	E-chg:	C-lod:	C-chg:	Displayed
FUL-Count: 0	LVD-Count: 0	10D	OKWH	OKWH	0AH	0AH	Displayed item/ parameter
Total number of full-charges	Total number of over-discharges	Total number of operating days	Total power consumption	Total power generation	Total discharging amp-hrs	Total charging amp-hrs	Description

### 10.7, Historical data of the current day

Historical data icon-




(Historical data including: the current day's min. battery voltage, the current day's max. battery voltage, the current day's max. charging current, the current day's max. discharging current, the current day's max. charging power, the current day's max. discharging power, the current day's charging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's total power generation and the current day's discharging amphrs, the current day's day and day amphrs, the current day's day amphrs, the current day's day amphrs, the current day amphr day's total power consumption)

Menu level	Page	Displayed item* parameter	Description
2st-level menu	1	<history data=""> xxxx Days Ago</history>	Xxxx : select the historical data of day xxxx (counting backwards) 0000: the current day 0001: yesterday 0002: the day before yesterday
		MinBatVol: 11.5V	The selected day's min. battery voltage
	i.	MaxBatVol: 11.6V	The selected day's max. battery voltage
	F	MaxChgVol: 0A	The selected day's max. charging current
		MaxLodVol: 0A	The selected day's max. discharging current
3st-level		MaxChgPow: 0W	The selected day's max. charging power
menu	ن	MaxLodPow: 0W	The selected day's max. discharging power
	_	C-D-Chg: 0AH	The selected day's total charging amp-hrs
		C-D-Lod: 0AH	The selected day's total discharging amp-hrs
	,	E-D-Chg: 0kWh	The selected day's total power generation
	u	E-D-Lod: 0kWh	The selected day's total power consumption

#### 10.8 Device information

Device information icon-



	menu	2st-level		Menu level
	1	<b>→</b>		Page
Serial:	SW-ver:	HW-ver :	Model :	
160300032	00.00.04	00.02.07	4845	Item
Controller serial number	Software version	Hardware version	Controller model	Description

#### 10.9, Bluetooth connection status

Bluetooth icon



Indicating a bluetooth connection status

 $ext{ }$  The App is only compatible with Android phones with an  $\circ$ S version of 4.3 or above and iphones.

## 11. Common Problems and Solutions

Symptoms	Causes and solutions
The screen won't light up after being turned on	Chack whother the population and the state of the state o
The screen is stuck at "Connecting"	is properly done and the controller functions normally, etc.
The fault indicator flashes quickly	Some abnormality occurs to the controller. Check the error code, pinpoint the cause, analyze and solve it.
The communication indicator flashes slowly	Communication between the display unit and controller is abnormal. Check the connection cable and controller,
"Disconnect"	The Bluetooth communication status is shown as:  1) The mobile App is not connected to the controller;  2) The device is visible to the mobile App's search, but the problem still lingers on Check the cable connecting the display unit and the controller;  3) The device is invisible to the mobile App's search. Check whether it has been paired with some other mobile phone; (Note: this menu is only available to the display units with the optional bluetooth function)

The contents of this manual are subject to change without prior notice.

Code:1.1.24.01469

according to the installation dimensions drawing in the User Manual. This installation assisting method is only applicable to panel installation. To ensure precision, drill holes

- Steps for usage:
- ② Apply the paper closely to the panel; ① Tear this page down, and take care not to damage the film:
- ③ Position and mark the points for drilling with the help of the 4 holes in the film, and then conduct drilling:
- Retrieve the paper, and install RM-5;

